

**Corrigendum-III**

**Dated: 18.06.19**

**Sub: “Supply, Installation and commissioning of 2 X 10 KVA Online UPS and all accessories required for their installation for VSS at various Railway Stations of Indian Railways for and on behalf of REL and Indian Railways”.**

Ref: (i) RailTel/Tender/OT/CO/P/2018-19/VSS/UPS/483 dated 10-05-19.

(ii) Corrigendum-II dtd: 12.06.19 & Corrigendum-I dtd 03.06.19

With reference to above tender, following changes has been done.

- (i) SN 7 of clause no 8.1, SOR-I of Chapter-8 (i.e Nominal voltage: 3x 400 V AC (3 Ph+ N) , may be read as:

“Deleted”

- (ii) SN 33 of clause no 8.1, SOR-I of Chapter-8 , may be read as:

Battery Shutdown Voltage : 10.5V X nos. of batteries.

- (iii) The date of submission of the bid has been extended up to 24.06.2019 at 15:00 Hrs.

Other terms & conditions are remained same.

**(Shaminder Singh)**

**Executive Director/Project**