

CORRIGENDUM No.1

Corrigendum no. 1 dated 01.04.2021

Tender no. **RCIL-E-Tender-20-21-SC-90** dt.29.03.2021

Name of the Work: "Supply and Installation of SMPS Battery Charger and VRLA Battery set for Telecom use in Railtel's OFC Network "

Item Description	As per Tender Document	To be Read as
Section-I(Variable) Chapter 4 Technical Requirements & Specifications clause D: DC distribution Box (DCDB) ((SOR-AI)): point-5	5.The material shall be MS with minimum 1.6mm thickness powder coated in light grey colour.	5.The material shall be MS with minimum 1.6mm thickness powder coated in light grey colour and the front panel of the box should be made with transparent and unbreakable material
1)Section-I Chapter-I(Price Schedule) Note 6 2) Section-I Chapter-3 (Special Tender Conditions) clause 3.3.1 (b)(ii) 3) Section-I Chapter-3 (Special Tender Conditions) clause 3.3.1 (b)(iii) 4) Section-I(Variable) Chapter 4 Technical Requirements & Specifications 5) Section-I(Variable) Chapter 4 Technical Requirements & Specifications C: 6) Section-I(Variable) Chapter 4 Technical Requirements & Specifications D: (ii)	1.VRLA/Tubular Gel 2. VRLA or Tubular Gel 3. VRLA/Tubular Gel 4. Tubular Gel/VRLA 5. Tubular Gel/VRLA 6. Tubular Gel/VRLA	1. VRLA 2. VRLA 3. VRLA 4. VRLA 5. VRLA 6. VRLA
All other terms and conditions of tender remain the same.		

Sd/-

(यशपालसिंहतोमर)

(Yashpal Singh Tomar)

महाप्रबंधकअनुरक्षण,संचालनऐवमपरियोजना/ दक्षिणक्षेत्र

General Manager/POM/SR

रेलटेलकॉरपोरेशनऑफइंडियालिमिटेड

RailTel Corporation of India Limited, Secunderabad