



Corrigendum-III dtd:06.10.2025

Ref: GeM Bid No. GEM/2025/B/6545095 Dated: 12.08.2025

Supply, Installation and Commissioning of 3KVA UPS for RailTel Western Region

Item Description	As per GeM Bid	To be read as
Date of Opening of tender as per Corrigendum II	Bid Closing date and Time: 10.10.2025 up to 15: 00 Hrs. Bid Opening date and Time: 10.10.2025 up to 15: 30 Hrs.	Bid Closing date and Time: 15.10.2025 up to 15: 00 Hrs. Bid Opening date and Time: 15.10.2025 up to 15: 30 Hrs.

SOR item 1: UPS Technical Specifications

SN	Particular	Specification		Compliance
		Old Clause	Revised Clause	
9	Type of Battery	SMF VRLA	SMF VRLA conforming to JSIC 8702	
9a	No. of Batteries	Nil	8 no. of 12 V- 7 AH	
10	Battery Back up	Minimum 30 minutes on full load (approx 6 Amp AC) with 1008 (minimum) VAH battery Size.	Deleted	
20	Mounting Mode	Rack Mountable	Rack Placement (to be kept horizontally within 9U rack)	
26	Environmental compliance	ROHS	ROHS, EPR-Plastic , EPR-Waste	
27	Rack Requirement	The bidder should ensure that the UPS with inbuilt battery is installed in a single 9U mountable rack.	The bidder shall ensure that the UPS with an inbuilt battery is installed within a single 9U rack. Rack Dimensions: 440mm (H) x 600mm(W) x 600mm (D)	
28	Standard Certification Required	Nil	ISO 9001, ISO14001,ISO 45001	
29	Communication			
29A	RS 232 port	Nil	Available	
29B	USB Com Port	Nil	Available	
29C	Intelligent Slot	Nil	SNMP/ MODBUS - Optional	

This is issued with the approval of Competent Authority.


Piyush Saxena

AGM/Procurement/WR
For RailTel Corporation of India Limited

रेलटेल कॉर्पोरेशन ऑफ़ इण्डिया लिमिटेड (भारत सरकार का एक उपक्रम, रेल मंत्रालय)

क्षेत्रीय कार्यालय : पश्चिम रेलवे माइक्रोवेव कॉम्प्लेक्स, सेनापती बापट मार्ग, महालक्ष्मी (प.), मुंबई ४०० ०१३, दूरभाष : ९१ २२ २४९२३९०७, फैक्स: ९१ २२ २४९२३९१३
पंजीकृत कार्यालय: प्लेट-ए, ६ व मंजिल, ऑफिस ब्लॉक, टावर -२, पूर्व किर्द्धाई नगर, नयी दिल्ली. -११००२३

RailTel Corporation of India Limited. (A Government of India Undertaking, Ministry of Railways)

Regional Office : Western Railway Microwave Complex, Senapati Bapat Marg, Mahalaxmi(W), Mumbai - 400 013. Tel.: +91 22 24923907, Fax : 91 22 24923913
Regd. Office: Plate-A, 6th Floor, Office Block, Tower-2, East Kidwai Nagar, New Delhi- 110023. Tel : 011 22185933-34. Fax : 011 22185978 Website: www.railtelindia.com

CIN : L64202DL2000GOI107905